

Declaration of test results

2012-Efectis-R9196c-D

Efectis Nederland BV hereby declares that:

the Permoxx construction identified as a load-bearing floor incorporating a ceiling of Permoxx board, two layers with a thickness of 9mm each insulated with Rockwool 201, was successfully tested with the Permoxx board at the exposed side. The construction has been tested according to **EN 1365-2:2001**. The dimensions of the construction were:

4000 x 3200 mm (w x h)

The test results classified to **EN 13501-2: 2009** are:

R30, RE60 and REI60

The complete details of the test performed, the results and the field of application are recorded in the Efectis test report 2012-Efectis-R9196c and classification report 2012-Efectis-R9196d.

This declaration is valid until:

September 2015

This declaration is issued to:

Permoxx Nederland B.V.
Kadijkselaan 11
2861 CG BERGAMBACHT

Place and date:

Rijswijk, 18 September 2012

On behalf of Efectis Nederland BV:



S. Lutz
Project Leader Fire Resistance